



State of California • Department of General Services • Gray Davis, Governor
DIVISION OF THE STATE ARCHITECT
Headquarters • 1130 K Street, Suite 101 • Sacramento, CA 95814 • (916) 445-8100

June 28, 2001

William F. Keller
Chief Engineer
Pacific Seismic Products, Inc.
223 East Avenue H-8
Lancaster, CA 93535-1621

Subject: Certification Earthquake Actuated Gas Shutoff Valves (Models Nos. 300, 301, 302, 303, 310, 311, 312, 313, 314, 314F, 315, 315F, 316, 316F, and 317F)

Dear Mr. Keller:

Pacific Seismic Products, Inc.'s request for certification of the subject valve(s) was approved and certified by this office on June 28, 2001 and is contingent upon the following:

1. Certification is based on the information supplied with the application which includes test data showing compliance with S.B. 12-16-1, California Standard for Earthquake Actuated Automatic Gas Shutoff Systems (Revised 2/2/01), Part 12, Title 24, California Code of Regulations (CCR) and gas valve drawings and specifications.
2. Compliance with section 1378, Subchapter 5, Title 21, CCR, regarding labels for gas valves. Final make-up and printing of tags, notice and box labels are to be provided to the Division of the State Architect (DSA) as required in Section 1378(e).
3. Quality control inspections to be conducted quarterly as required in Section 1382(e), Title 21, CCR, and at least one such inspection shall occur in each production run of no less than three months duration.
4. Verified Inspection Reports are to be sent to DSA within 30 days of date of inspection.
5. If any changes occur in the manufacturing of the product, company ownership or any other changes as noted in Sections 1371 through 1385, Title 21, CCR, occur, DSA is to be notified in writing within 30 days of the change or the DSA certification becomes invalid.
6. This certification will remain in force until it is revoked by DSA.
7. The following numbers (04R, 05R, 45R) and Item Numbers (30R, 31R, 32R, 33R, 10R, 11R, 12R, 13R, 14R, 15R, 16R, 113R).

If you have any questions concerning this certification, please call me at (916) 324-7180 or Patrick Campbell at (916) 324-7183.

Sincerely,

A handwritten signature in black ink, appearing to read 'R. J. Conrad'.

Richard Conrad, Manager
Technical Services